

# Effect of Distribution Automation on Protective Relaying

---

Power System Relay Committee  
September 11, 2014

Presented by Fred Friend



# Working Group D11

---

## **Chair – Fred Friend**

**Brian Mugalian  
Calin Micu  
Charles Sufana  
Cheong Siew  
Claire Patti  
Daniel Goodrich  
Don Lukach  
Don Parker  
Farajollah Soudi  
Jack Jester  
Jakov Vico  
Jay Sperl**

## **Vice Chair – Gerald Johnson**

**John Tengdin  
Juan Gers  
Kevin Donahoe  
Matt Black  
Mike Meisinger  
Pat Heavey  
Patrick Carroll  
Raluca Lascu  
S.S. Mani Venkata  
Steven Hodder  
Victor Ortiz  
Wayne Hartmann**

# Effect of Distribution Automation on Protective Relaying

---

- Introduction
- History of Distribution Automation
- Effects on Application and Settings
- Impact of System Maintenance
- Bibliography and Annexes



# Effect of Distribution Automation on Protective Relaying

---

# Introduction

---

## □ Origins of the Paper

### ■ IEEE Power System Relaying Committee

#### □ Working Group D11 (D-Line Protection Subcommittee)

□ Purpose: Explore the effect of distribution automation on protective relaying applied on primary, non-network, distribution systems

□ DA defined as sectionalization and reconfiguration of distribution circuits using:

- Auto or remote controlled transfer switches
- Reclosers, fault interrupters, sectionalizers, cap controls, etc

# History of Distribution Automation

---

## □ Substation Based Automation

### ■ Supervisory Control

- Used in Subs w/ coms to Manned Control Center
- Typically leased telephone circuits
- Remotely monitored & controlled Feeder Breakers
- Included status of each breaker
- Monitored one phase current/bkr & voltage
- Monitoring and control of Cap banks & some LTCs
- Expensive for distribution sub applications

# History of Distribution Automation

---

## □ Substation Based Automation

### ■ Project PROBE

- 1974 **P**ower **R**esource **O**ptimization **B**y **E**lectronics
- Varian V-72 mini computer 1974-78 La Grange Park Sub

### ■ Probe Phase 2

- Varian V-77 mini computer
- 1978-80 First application of integrated volt/var profile
- Used to flatten feeders voltage profile

### ■ Later, EPRI Project RP 1472-1

- Prototype Microprocessor Relays, DPM (Distribution Protection Module) had six functions 50, 51, 79, 50BF, 25, 81

# History of Distribution Automation

---

## □ Line Distribution Automation

### ■ Remote Monitoring and Control

- Evolved to include motor operated switches, line reclosers, line caps & regulators and defined a need for monitoring I & V at newly monitored devices

### ■ New Current and Voltage Sensors Developed

- Look of line post insulator
- Less bulky and costly
- With sensing on feeders, more data was available for locally operated logic blocks

### ■ On-board Logic

### ■ Microprocessor-based Relays

# History of Distribution Automation

---

## □ Microprocessor-based Relays

- Developed pole mounted controls for reclosers
- Perform protection & communications simultaneously
- Feasible to perform fault isolation and feeder reconfigure without control center intervention
- Allows switching portion of one feeder to another
- Settings Groups to Enable Reconfiguration
- Action Based on Dynamic Current Ratings
- Single-Phase and Three-Phase Recloser Operation
- Coordination issues with legacy relays



# Today's Distribution Automation Applications

---

- Remote Monitoring
  - SCADA Protocols
  - Fault detection
  - Circuit & Load Measurements
- Remote Monitoring with Control
- With Circuit Reconfiguration
- Reporting
- Evaluation
- DA Schemes Vary in Degree of Complexity

# Hierarchy of Intelligence

- Local
- Distributed
- Central




# Hierarchy of Intelligence


---

## □ Local

- Minimal Communication Between Devices
- Functionality Contained Within the Device
- Occurs Based on External Conditions (V-I-Position)



# Local Intelligence




# Hierarchy of Intelligence

---

## □ Distributed Intelligence

- Decentralized Intelligence
- Communication & Software Between Devices
- Provides Automated Control Within Defined Area
- Shared Software & Communications distribute data
- Utilizes Data Inputs From Communicating Devices

# Intelligent Communication



# Hierarchy of Intelligence

---

## □ Centralized Intelligence

- Concepts are applied across larger control areas
- Scheme determines optimal switching sequences
- Numerous possibilities have to be analyzed
  - In advance & logic designed into central controller
- Intelligence Resides at a Remote Location
  - Control or Data Center
- Reliable, robust, secure communication system required



# Central Intelligence

Volt-Var Optimization


Dynamic Equipment Rating

Optimal Network Configuration

Fault Location Isolation and Service Restoration

# Effects on Application and Settings

- Circuit Reconfiguration
- Protection Considerations



# Circuit Reconfiguration

---

## □ Proactive

- Prepare circuits for permanent or temporary change
  - To improve the operating condition of the system
- Driving Factors
  - Improve voltage profile
  - Energy loss reduction
  - Maintenance or repair
  - Temporary Overload
- Relaying has been assessed and changes made

# Circuit Reconfiguration

---


- Automatic (Reactive)
  - Reaction to system condition
  - Requires automatic control & intelligence to analyze fault condition
  - Provide alternate to restore max number of customers
  - May require new preprogrammed protection settings, new setting group or reverse power protection

# Circuit Reconfiguration Protection Considerations

---


- ❑ FLISR must coordinate with auto reclosing
- ❑ Reconfiguration may need final reclosing shot
- ❑ Reconfiguration may need revised protection
- ❑ DA must distinguish between fault and non-fault or abnormal operations

# Load Sectionalizing Considerations




\* Preferred Location for Tie Switch

SECTIONALIZING SWITCH




● Normally Closed (NC)  
○ Normally Open (NO)

DOUBLE DEADEND



# Load Sectionalizing Considerations



# Possible Issues with Serving Load

---

- Close-Transition Switching
  - Voltage differences
  - Short circuit levels
- Changes in Load without Relay Changes
  - Overloaded devices
- Reverse Power Flow
  - Non directional relays
- Network Configuration

# Fault Location, Isolation, and Service Restoration

---

## □ FLISR Process

- Fault is detected, current source removed
- Fault is located and switches isolate it
- Upstream restoration
- Downstream restoration
- Faulted section repaired and system returned to normal




# FLISR Requirements


---

- ❑ Transformer and line currents remain within specified limits
- ❑ Voltage drop stays inside an established margin
- ❑ A radial system is maintained
- ❑ Reduce number of equipment operations
- ❑ System balance is maintained
- ❑ Protection coordination is maintained
- ❑ System protection maintained for all reconfigurations
- ❑ Harmonic content and power factor are within established limits

# FLISR



# FLISR



# Protection Considerations

---

- Multiple Settings Groups – D and T
- Adaptive Relay Applications and Considerations
- Zone of Protection
  - Instantaneous Overcurrent
  - Time Delayed Overcurrent
  - Cold Load Pickup
  - Arc Flash Requirements
- Fuse Saving/Sacrificing
- Distance to Fault Calculation

# Protection Considerations - DR

---

- Radial Design at the Source
- Radial Design on the Line
- Sync-Check
- Islanding Concerns on Reconfiguration
- Pilot Schemes
- Apparent Impedance
- Zero Sequence Influence

# System Maintenance

---


- Documentation
- Lock Out Tag Out Procedures
- Physical Security
- Remote Location Maintenance
- Master Station Maintenance



# Remote Location Maintenance

---


- Environmental Damage
- Battery System
- Error Logs
- Communication System
- Operate Bypass



# Master Station Maintenance

---

- Battery System
- Nuisance Event Process
- Communication System
- Database Maintenance




# Bibliography

---

- 24 References
- 44 Different Authors
- 36 Years



# Annex A – Changes of Power Flow Due to Different Topology Scenarios



# Annex B – One Company's History with Distribution Automation

---

- Duquesne Light Company
- 14 aspects to protecting the distribution circuit
- 5 point philosophy for the distribution system
- Operating experience
- Results
- Conclusions

# Questions?

